CIVIL PRO
AN ISO 9001 : 2008 COMPANY &NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Date: 06/12/2018

Lab ID	:	**CP-2018-12-03-05**
Project Name	:	Construction of Swimming Pool at Amrutha Nagara Byatarayanapura Ward No.07
Agency	:	Sri.K.Somappa No.139/A,6th Main Mathikere,Bangalore-560054
Customer's Reference	:	EE(Project)/Ynk Zone/wo/12/2018-19
Date of Receipt	:	01-12-18
Customer ID	:	Balancing Tank Wall Concrete
Sample Type /Size	:	150X150X150 mm
Sample grade/Age	:	M25 / 7 Days Compressive Strength
Reference to BIS codes	:	IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5
Date of test	:	06/12/2018

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
1	Bulancing Tank Wall Concrete	M25	29/11/2018	06/12/2018	149.49 X 151.46 X 151.02	22641	**8.295**	528.1	23.3	22.8
2	Bulancing Tank Wall Concrete	M25	29/11/2018	06/12/2018	151.70 X 151.69 X 151.59	23011	**8.939**	515.3	22.4	
3	Bulancing Tank Wall Concrete	M25	29/11/2018	06/12/2018	149.88 X 149.76 X 151.09	22447	**8.499**	510.5	22.7	

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

CIVIL PRO BANGALORE Sig..... Date.....

Page 1/1
****End of Report****

CIVIL PRO
AN ISO 9001 : 2008 COMPANY &NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Date: 27/12/2018

Lab ID	:	**CP-2018-12-03-05**
Project Name	:	Construction of Swimming Pool at Amrutha Nagara Byatarayanapura Ward No.07
Agency	:	Sri.K.Somappa No.139/A,6th Main Mathikere,Bangalore-560054
Customer's Reference	:	EE(Project)/Ynk Zone/wo/12/2018-19
Date of Receipt	:	01-12-18
Customer ID	:	Balancing Tank Wall Concrete
Sample Type /Size	:	150X150X150 mm
Sample grade/Age	:	M25 / 28 Days Compressive Strength
Reference to BIS codes	:	IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5
Date of test	:	27/12/2018

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
1	Balancing Tank Wall Concrete	M25	29/11/2018	27/12/2018	151.05 X 149.89 X 150.61	22641	**8.678**	624.2	27.6	27.6
2	Balancing Tank Wall Concrete	M25	29/11/2018	27/12/2018	151.16 X 151.59 X 150.79	22916	**8.855**	614.9	26.8	
3	Balancing Tank Wall Concrete	M25	29/11/2018	27/12/2018	150.11 X 151.04 X 151.82	22673	**8.299**	645.7	28.5	

Asst. Executive Engineer,
Project Division
Yelahanka Zone
Bangalore

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

CIVIL PRO BANGALORE
Sig.....
Date.....

Page 1/1
****End of Report****

CIVIL PRO
AN ISO 9001 : 2008 COMPANY &NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Lab ID : **CP-2018-12-03-05** **Date: 10/12/2018**

Project Name : Construction of Swimming Pool at Amrutha Nagara Byatarayanapura Ward No.07

Agency : Sri.K.Somappa No.139/A,6th Main Mathikere,Bangalore-560054

Customer's Reference : EE(Project)/Ynk Zone/wo/12/2018-19

Date of Receipt : 05-12-18

Customer ID : Balancing Tank Top Slab Concrete

Sample Type /Size : 150X150X150 mm

Sample grade/Age : M25 / 7 Days Compressive Strength

Reference to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

Date of test : 10/12/2018

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
1	Balancing Tank Top Slab Concrete	M25	03/12/2018	10/12/2018	149.55 X 149.65 X 149.14	22381	**8.984**	518.9	23.2	22.8
2	Balancing Tank Top Slab Concrete	M25	03/12/2018	10/12/2018	151.50 X 150.36 X 150.51	22779	**8.113**	516.9	22.7	
3	Balancing Tank Top Slab Concrete	M25	03/12/2018	10/12/2018	149.03 X 151.55 X 151.72	22586	**8.742**	505.8	22.4	

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

CIVIL Pro Sig..... Date..... BANGALORE

****End of Report****

M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL | GEO TECHNICAL | PROJECT MANAGEMENT | SURVEYING SERVICES |

CIVIL PRO
AN ISO 9001 : 2008 COMPANY &NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Date: 31/12/2018

Lab ID	:	**CP-2018-12-03-05**
Project Name	:	Construction of Swimming Pool at Amrutha Nagara Byatarayanapura Ward No.07
Agency	:	Sri.K.Somappa No.139/A,6th Main Mathikere,Bangalore-560054
Customer's Reference	:	EE(Project)/Ynk Zone/wo/12/2018-19
Date of Receipt	:	05-12-18
Customer ID	:	Balancing Tank Top Slab Concrete
Sample Type /Size	:	150X150X150 mm
Sample grade/Age	:	M25 / 28 Days Compressive Strength
Reference to BIS codes	:	IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5
Date of test	:	31/12/2018

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
1	Balancing Tank Top Slab Concrete	M25	03/12/2018	31/12/2018	149.90 X 150.27 X 151.70	22526	**8.749**	623.5	27.7	27.5
2	Balancing Tank Top Slab Concrete	M25	03/12/2018	31/12/2018	151.19 X 149.99 X 149.46	22678	**8.196**	595.5	26.3	
3	Balancing Tank Top Slab Concrete	M25	03/12/2018	31/12/2018	150.46 X 150.81 X 150.05	22690	**8.630**	645.7	28.5	

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

CIVIL PRO BANGALORE Sig..... Date.....

Page 1/1
****End of Report****

CIVIL PRO
AN ISO 9001 : 2008 COMPANY &NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Date: 10/12/2018

Lab ID	:	**CP-2018-12-03-05**
Project Name	:	Construction of Swimming Pool at Amrutha Nagara Byatarayanapura Ward No.07
Agency	:	Sri.K.Somappa No.139/A,6th Main Mathikere,Bangalore-560054
Customer's Reference	:	EE(Project)/Ynk Zone/wo/12/2018-19
Date of Receipt	:	05-12-18
Customer ID	:	Balancing Tank Top Slab Concrete
Sample Type /Size	:	150X150X150 mm
Sample grade/Age	:	M25 / 7 Days Compressive Strength
Reference to BIS codes	:	IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5
Date of test	:	10/12/2018

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
1	Balancing Tank Top Slab Concrete	M25	03/12/2018	10/12/2018	149.47 X 150.03 X 149.96	22425	**8.181**	530.8	23.7	22.6
2	Balancing Tank Top Slab Concrete	M25	03/12/2018	10/12/2018	150.75 X 150.30 X 151.33	22657	**8.665**	499.8	22.1	
3	Balancing Tank Top Slab Concrete	M25	03/12/2018	10/12/2018	151.61 X 150.05 X 151.76	22749	**8.531**	503.6	22.1	

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

FOR CIVIL Pro

R KARTHIK RECHA
Authorized Signato
Quality Manag

CIVIL PRO BANGALORE Sig..... Date.....

Page 1/1
****End of Report****

CIVIL PRO
AN ISO 9001 : 2008 COMPANY &NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Lab ID : **CP-2018-12-03-05** **Date: 31/12/2018**

Project Name : Construction of Swimming Pool at Amrutha Nagara Byatarayanapura Ward No.07

Agency : Sri.K.Somappa No.139/A,6th Main Mathikere,Bangalore-560054

Customer's Reference : EE(Project)/Ynk Zone/wo/12/2018-19

Date of Receipt : 05-12-18

Customer ID : Balancing Tank Top Slab Concrete

Sample Type /Size : 150X150X150 mm

Sample grade/Age : M25 / 28 Days Compressive Strength

Reference to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

Date of test : 31/12/2018

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
1	Balancing Tank Top Slab Concrete	M25	03/12/2018	31/12/2018	149.40 X 151.27 X 149.00	22600	**8.969**	619.2	27.4	27.4
2	Balancing Tank Top Slab Concrete	M25	03/12/2018	31/12/2018	149.86 X 149.65 X 149.85	22426	**8.882**	597.1	26.6	
3	Balancing Tank Top Slab Concrete	M25	03/12/2018	31/12/2018	150.74 X 149.32 X 150.21	22509	**8.313**	632.3	28.1	

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

****End of Report****

CIVIL PRO BANGALORE Sig..... Date.....

M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

CIVIL PRO
AN ISO 9001 : 2008 COMPANY &NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Date: 12/12/2018

Lab ID : CP-2018-12-03-05
Project Name : Construction of Swimming Pool at Amrutha Nagara Byatarayanapura Ward No.07
Agency : Sri.K.Somappa No.139/A,6th Main Mathikere,Bangalore-560054
Customer's Reference : EE(Project)/Ynk Zone/wo/12/2018-19
Date of Receipt : 07-12-18
Customer ID : Drain Bottom Slab Concrete
Sample Type /Size : 150X150X150 mm
Sample grade/Age : M25 / 7 Days Compressive Strength
Reference to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5
Date of test : 12/12/2018

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
1	Drain Bottom Slab Concrete	M25	05/12/2018	12/12/2018	151.78 X 151.54 X 149.61	23002	**8.161**	550.5	23.9	22.7
2	Drain Bottom Slab Concrete	M25	05/12/2018	12/12/2018	151.02 X 149.14 X 149.45	22524	**8.953**	497.6	22.1	
3	Drain Bottom Slab Concrete	M25	05/12/2018	12/12/2018	150.41 X 149.84 X 151.84	22537	**8.387**	498.3	22.1	

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

CIVIL PRO BANGALORE Sig..... Date.....

Page 1/1
****End of Report****

CIVIL PRO
AN ISO 9001 : 2008 COMPANY &NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Date: 02/01/2019

Lab ID	:	**CP-2018-12-03-05**
Project Name	:	Construction of Swimming Pool at Amrutha Nagara Byatarayanapura Ward No.07
Agency	:	Sri.K.Somappa No.139/A,6th Main Mathikere,Bangalore-560054
Customer's Reference	:	EE(Project)/Ynk Zone/wo/12/2018-19
Date of Receipt	:	07-12-18
Customer ID	:	Drain Bottom Slab Concrete
Sample Type /Size	:	150X150X150 mm
Sample grade/Age	:	M25 / 28 Days Compressive Strength
Reference to BIS codes	:	IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5
Date of test	:	02/01/2019

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
1	Drain Bottom Slab Concrete	M25	05/12/2018	02/01/2019	150.36 X 150.06 X 150.36	22563	**8.852**	630.3	27.9	27.8
2	Drain Bottom Slab Concrete	M25	05/12/2018	02/01/2019	149.63 X 150.31 X 150.29	22491	**8.601**	601.8	26.8	
3	Drain Bottom Slab Concrete	M25	05/12/2018	02/01/2019	151.51 X 149.35 X 150.87	22627	**8.969**	648.8	28.7	

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

CIVIL PRO BANGALORE Sig..... Date.....

Page 1/1
****End of Report****

CIVIL PRO
AN ISO 9001 : 2008 COMPANY &NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Date: 29/12/2018

Lab ID	:	**CP-2018-12-03-05**
Project Name	:	Construction of Swimming Pool at Amrutha Nagara Byatarayanapura Ward No.07
Agency	:	Sri.K.Somappa No.139/A,6th Main Mathikere,Bangalore-560054
Customer's Reference	:	EE(Project)/Ynk Zone/wo/12/2018-19
Date of Receipt	:	24-12-18
Customer ID	:	Plinth Beam Concrete
Sample Type /Size	:	150X150X150 mm
Sample grade/Age	:	M25 / 7 Days Compressive Strength
Reference to BIS codes	:	IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5
Date of test	:	29/12/2018

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
1	Plinth Beam Concrete	M25	22/12/2018	29/12/2018	150.28 X 149.62 X 150.70	22485	**8.597**	521.3	23.2	22.5
2	Plinth Beam Concrete	M25	22/12/2018	29/12/2018	149.18 X 150.81 X 149.07	22498	**8.972**	497.8	22.1	
3	Plinth Beam Concrete	M25	22/12/2018	29/12/2018	151.29 X 149.06 X 150.99	22552	**8.764**	498.4	22.1	

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

CIVIL PRO BANGALORE
Sig.....
Date.....

Page 1/1
****End of Report****

CIVIL PRO
AN ISO 9001 : 2008 COMPANY &NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Date: 19/01/2019

Lab ID	:	**CP-2018-12-03-05**
Project Name	:	Construction of Swimming Pool at Amrutha Nagara Byatarayanapura Ward No.07
Agency	:	Sri.K.Somappa No.139/A,6th Main Mathikere,Bangalore-560054
Customer's Reference	:	EE(Project)/Ynk Zone/wo/12/2018-19
Date of Receipt	:	24-12-18
Customer ID	:	Plinth Beam Concrete
Sample Type /Size	:	150X150X150 mm
Sample grade/Age	:	M25 / 28 Days Compressive Strength
Reference to BIS codes	:	IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5
Date of test	:	19/01/2019

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
1	Plinth Beam Concrete	M25	22/12/2018	19/01/2019	150.65 X 150.78 X 150.31	22714	**8.117**	616.2	27.1	27.4
2	Plinth Beam Concrete	M25	22/12/2018	19/01/2019	150.62 X 150.47 X 151.31	22663	**8.187**	592.0	26.1	
3	Plinth Beam Concrete	M25	22/12/2018	19/01/2019	150.45 X 150.80 X 151.82	22688	**8.588**	654.2	28.8	

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

CIVIL Pro BANGALORE Sig..... Date.....

****End of Report****

M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL | GEO TECHNICAL | PROJECT MANAGEMENT | SURVEYING SERVICES |

CIVIL PRO
AN ISO 9001 : 2008 COMPANY &NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Lab ID : **CP-2018-12-03-05** **Date: 29/12/2018**

Project Name : Construction of Swimming Pool at Amrutha Nagara Byatarayanapura Ward No.07

Agency : Sri.K.Somappa No.139/A,6th Main Mathikere,Bangalore-560054

Customer's Reference : EE(Project)/Ynk Zone/wo/12/2018-19

Date of Receipt : 24-12-18

Customer ID : Plinth Beam Concrete

Sample Type /Size : 150X150X150 mm

Sample grade/Age : M25 / 7 Days Compressive Strength

Reference to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

Date of test : 29/12/2018

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
1	Plinth Beam Concrete	M25	22/12/2018	29/12/2018	150.85 X 150.28 X 151.52	22670	**8.729**	529.7	23.4	23.0
2	Plinth Beam Concrete	M25	22/12/2018	29/12/2018	150.95 X 150.17 X 149.08	22667	**8.222**	517.3	22.8	
3	Plinth Beam Concrete	M25	22/12/2018	29/12/2018	151.63 X 150.24 X 149.71	22781	**8.952**	523.0	23.0	

Asst. Executive Engineer
Project Division
Yelahanka Zone
Bangalore

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

CIVIL PRO BANGALORE Sig..... Date.....

Page 1/1
****End of Report****

CIVIL PRO
AN ISO 9001 : 2008 COMPANY &NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Date: 19/01/2019

Lab ID : **CP-2018-12-03-05**
Project Name : Construction of Swimming Pool at Amrutha Nagara Byatarayanapura Ward No.07
Agency : Sri.K.Somappa No.139/A,6th Main Mathikere,Bangalore-560054
Customer's Reference : EE(Project)/Ynk Zone/wo/12/2018-19
Date of Receipt : 24-12-18
Customer ID : Plinth Beam Concrete
Sample Type /Size : 150X150X150 mm
Sample grade/Age : M25 / 28 Days Compressive Strength
Reference to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5
Date of test : 19/01/2019

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
1	Plinth Beam Concrete	M25	22/12/2018	19/01/2019	151.57 X 151.50 X 150.85	22964	**8.188**	621.2	27.1	27.5
2	Plinth Beam Concrete	M25	22/12/2018	19/01/2019	149.14 X 151.77 X 151.84	22636	**8.764**	602.6	26.6	
3	Plinth Beam Concrete	M25	22/12/2018	19/01/2019	149.49 X 149.21 X 149.88	22306	**8.228**	643.2	28.8	

Asst Executive Engineer
Project Division
Yelahanka Zone
Bangalore

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

CIVIL PRO BANGALORE Sig..... Date.....

Page 1/1
****End of Report****